



## Product certificate K96233/02

Issued 2018-03-01

Replaces K96233/01

Page 1 of 2

### Underground fire hydrants

#### STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

### Appendagefabriek Kolk B.V.

as specified in this product certificate and marked with the Kiwa<sup>®</sup>-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with

**Kiwa evaluation guideline BRL-BRL-K614/04:** "Fire hydrants" dated 01-10-2015.

as well as to:

**EN 14339:** Underground fire hydrants.

Luc Leroy  
Kiwa

288171015

*Publication of this certificate is allowed.*

*Advice: consult [www.kiwa.nl](http://www.kiwa.nl) in order to ensure that this certificate is still valid.*

#### Kiwa Nederland B.V.

Sir Winston Churchilllaan 273

P.O.Box 70

2280 AB RIJSWIJK

The Netherlands

Tel. +31 88 998 44 00

Fax +31 88 998 44 20

[info@kiwa.nl](mailto:info@kiwa.nl)

[www.kiwa.nl](http://www.kiwa.nl)

#### Company

Appendagefabriek Kolk B.V.

Parelstraat 5

7554 TL HENGELO OV

Tel. 074-2918961

[www.kolkbv.nl](http://www.kolkbv.nl)



Certification process  
consists of initial and  
regular assessment of:

- quality system
- product

## Underground fire hydrants

---

### Technical specification

The products mentioned below belong to this certificate

#### Underground Fire Hydrant

BEP-iP (N)

DN80

PN16

Ground cover 0,75 en 1m

---

### Application and use

The fire hydrants are intended to be used as a device for extinguishing water, connected to the distribution network or to drinking water installations with a working pressure of maximum 1.000 kPa and a water temperature of maximum of 30°C.

---

### Toxicological requirements

The toxicological requirements for products coming into contact with drinking water are laid down in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" (Regulation materials and chemicals for drinking water and warm tap water supply; published in the Government Gazette).

This product is not completely evaluated according to above mentioned regulation. Parts of the product that meet the requirements of above mentioned regulation are recorded in the Appendix to the certificate.

---

### Marking

The Kiwa®-mark products are marked with the word mark "KIWA".

Place of the mark: on the body or identification plate

Compulsory specifications:

For underground and pillar hydrants:

- Reference to EN 14339 for underground hydrants
- DN
- PN
- Loose obturator (for underground hydrants only)
- Manufacturers mark
- Date of manufacture
- Designation letter

Method of marking:

- Non-erasable;
- visible after assembly.

### RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Appendagefabriek Kolk B.V.
- and, if necessary,
- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.